

Drainfield Square Footage Required Minimum

Flow/Sq Ft	500	600	625	750	875	900	1050	1125	1350	1575
2.5'	76.92	92.30	96.15	115.38	134.61	138.48	161.53	173.07	207.69	242.30
3.0'	66.66	80.00	83.33	100.00	116.66	120.00	140.00	150.00	180.00	210.00
3.5'	58.32	70.58	73.52	88.23	102.94	105.88	123.52	132.35	158.82	185.29
4.0'	52.63	63.15	65.78	78.94	92.11	94.73	110.52	118.42	142.10	165.78
4.5'	47.61	57.14	59.52	71.42	83.33	85.71	100.00	107.14	128.57	150.00
5.0	43.47	52.17	54.34	65.21	76.03	78.26	96.30	97.82	117.39	136.95

Percolation Rates (nearest MPI)

	1-5	6-30	31-60	Repairs only 61-120
1 Bedroom	500	600	900	2150
2 Bedroom	625	750	1125	2700
3 Bedroom	750	900	1350	3250
4 Bedroom	875	1050	1575	3750
Additional Bedrooms	125	150	225	550